

March 2016 Utility Report

Water:

Samples to Tyler

State quarterly samples @ East Well.

Repaired leak @ North Well clay valve.

Repair chlorine room exhaust fan @ North Well.

Wastewater Treatment Plant

Cleaned out drying beds.

Waste Sludge.

Replaced 80 plus feet of collection line on Mockingbird.

Meet with Engineers to draw system map for RTCR required by TCEQ.

Repaired 5 feet of collection line on Gibson St.

Repaired I & I problems at customers tap 2 places.

Customer WW service line blocked on Orchard.

Misc.

Ditch work on Kirby and Mockingbird.

Removed trees on Mockingbird.

Mow/Weed eat