



Water/Wastewater Report

Water Department Report

The water department produced 2,349,062 gallons of water, for a daily average of 78,302 gallons in the month of September.

For the month of August by comparison, produced 2,884,582 gallons of water, for an average of 93,051 gallons per day.

Flushing of the dead end mains used 11,200 gallons of water.

Worked on the EPP grant.

The water tower has an air conditioner cooling it, is functioning properly.

Frontier Communication line error causing the East Well to be shut down for a few day's.

Three new water tap installed.

Water leak in 3 places

Worked on CCR

Wastewater Department Report

The Wastewater department treated 1.50 million gallons for the month September.

This month's DMR should reflect no flow violation.

Patched streets and installed "No Thru Truck" signs.

ALS lift-station took damage to roof. Waiting on quote for repair's. Pump's are working and no issues inside building.

Hauled off full container of dry sludge. New container delivered.

Number 5 frog in second lagoon is still down. Waiting for repair's to be made to return to work.

Lots of mowing and weed eating.

Customer sewer blockage in 0 places.